

MOBILE HOME METER POLE EMC DIAGRAM 5.

Updated: 07_09_05

- NOTE -

1. The National Electrical Code requires an insulated neutral and separate ground for mobile homes.
2. Minimum ground clearance to service attachment is 16'. However, additional clearance is needed for drives, roadways, etc. Refer to Section 3-2 of handbook.
3. The mobile home service equipment shall be located adjacent to the mobile home and not mounted in or on the mobile home. NEC 550-3.

