

TEMPORARY SERVICE POLE EMC DIAGRAM 6.

- NOTE -

1. Ground clearance shall be in accordance with Section 3-2 of handbook.

Guy-wire attachment (if required by Engineer) - attach a ¼" cable to top of pole and attach the other end of the cable to suitable anchorage installed 10' from the base of the pole.

